



Comité d'examen des répercussions
sur l'environnement et le milieu social

ᑭᑦᑎᑦᑎᑦᑎᑦᑎᑦᑎᑦ
ᑭᑦᑎᑦᑎᑦᑎᑦᑎᑦᑎᑦ
ᑭᑦᑎᑦᑎᑦᑎᑦᑎᑦᑎᑦ

COURTESY TRANSLATION

Isaac Voyageur
Regional Administrator
Cree Regional Authority
32 Amisk St., 3rd floor
Mistissini QC G0W 1C0

**SUBJECT: Project: Eastmain water supply system and increase in the capacity of the drinking water filtration plant using Beaver Creek, Phase II
Request to amend the certificate of authorization
3214-11-99B**

Dear Mr. Voyageur:

The Review Committee (COMEX) has studied the information you sent it on May 13, 2015 regarding the above-mentioned project.

Considering all of the information received in relation to the project, COMEX, in accordance with section 162 of the *Environment Quality Act* and paragraph 22.6.13 of the James Bay and Northern Québec Agreement, recommends that you authorize the project. However, special attention must be paid to monitoring trihalomethane (THM) and haloacetic acid (AHA) concentrations in drinking water. Monitoring reports must be submitted to the competent authorities and MDDELCC can be asked for assistance where necessary.

Yours truly,

André Boisclair
Chairman
Environmental and Social Impact
Review Committee (COMEX)